

HYDRANT 5-0664

Water: Form ☒

Belleville ave. W.S. Nx Belleville rd. St.

Make AM.-Darl. Pattern B-62-B

Set Sept. 29, 1994 Size 5 1/4" Bell 6"

Valve Nozzles 1S 2H Nt. Pressure 67 lbs.

Cross-over Gate 1st. Gate W X EL. 46.9'

2nd Gate E x WL. 28.6'

N from N line Belleville rd. St. 203.0 ft.

E from W line Belleville ave. St. 8.8 ft.

Gate E x Ctr. of Hydt. 2.4'

J-26

OPEN TO THE RIGHT