



PERMIT NO.
24921

CITY OF NEW BEDFORD
SEWER AND/OR STORM DRAIN PERMIT

DATE 2/2/90
2/4/2021

This certifies that permission is granted to

Stephen Brown 116 Bedford St NB 02740
Property Owner Address Tel. 81-724-3810

To connect a sewer and/or storm drain located at 116 Bedford St NB
Assessor's Plot 411 Lot 134 to the sewer and/or storm drain in Bedford St Street

To be laid in accordance with the conditions in this application and the City of New Bedford ordinances.

TYPE OF USE: RESIDENTIAL COMMERCIAL INDUSTRIAL FLOW G.P.D.

If applicant other than actual property owner, attach Letter of Authorization from Property Owner.

Name: Canessa Excavating Tel. 508-998-3404

Mailing Address: P.O. Box 51643 NB NB

The Bonded Contractor/Drain Layer authorized to perform this work is:

Name: RJ Canessa Address: 6 SDR 35 Tel. 508-998-3404

Type of Pipe Required: 6 SDR 35

PERMIT EXPIRES ONE YEAR AFTER DATE OF ISSUE

- Requires separate connections for sewage and storm drain where applicable. Storm water cannot be discharged to a sanitary sewer.
- All work must be inspected and approved by a D.P.I. inspector before backfilling.
- If this connection is to be part of a private service shared jointly with other building owners, attach copy of Recorded Joint Maintenance Agreement.
- Permits can be issued to Industrial and/or Commercial Applicants only upon receipt and approval by the Commissioner of Public Infrastructure of required plans and supplemental information.
- In addition, a City-issued Industrial User Discharge Permit and/or a Sewer Extension/Connection Permit issued by the Commonwealth of Massachusetts D.E.P. shall be required by the City for Industrial Discharge into the sewer system.

Comm. Mass. Sewer Conn./Ext. Permit No. Date.

A Filing and Inspection Fee of \$450 plus an Entrance Fee of \$ where applicable, must accompany this application.

Bank# BayCoast Check# 11554 Date 2-4-2021 Receipt#

Other requirements:

Connection made to Sewer Storm Drain Part of jointly-shared private line YES NO

Applicant agrees to abide by the above terms, as well as all pertinent ordinances of the City of New Bedford, and such other special rules as the Commissioner of Public Infrastructure and/or City Engineer may deem necessary.

* Stephen Canessa City Engineer * R. Canessa Signature of Property Owner or Representative

INSPECTOR'S REPORT

INSPECTED BY:


DATE:

COMMENTS:

APPROVED

DISAPPROVED

SIGNATURE



SKETCH PLAN

RT CANESSA EXCAVATING
Cell # 508-916-1144

ANTHONY ST.

New Sewer Connection Plan for
116 Bedford St.
Feb. 5, 2021

Existing Sewer Manhole
Depth to Invert 7' 4" ±

NORTH

Bedford ST

EXISTING 8" CLAY Sewer Main

20' ← Proposed 6" sdr 35
Sewer Service Slope = 2%

concrete Sidewalks

← Proposed 6" PVC Sewer

Driveway

CLEANOUT 1 FT INTO CITY
LAYOUT WITH CAST IRON
COVER

30'

116 Bedford St

← Broken Existing Clay Sewer
Going South Through
Neighbors Property
NO EASEMENT.