

APPLICATION/AGREEMENT
For Trench/Disturbance Permit within the City of New Bedford

Permit # 381-2033
Dig Safe#20221200733
Date: 3/21/2022

TO THE MAYOR AND CITY COUNCIL: DISTURBANCE PERMIT/TRENCH SAFETY PERMIT

Permission is hereby requested to excavate the surface of: X City Property and/or X Private Property
Provide Sketch

Location of Work: 786 Belleville Ave.

intersection of Belleville Ave x Howard Ave

Emergency Gas Leak Repair

Work will begin (weather permitting) on: March 21, 2022

Applicant Name: Kevin O'Sullivan (ra) Excavator(s) Name: _____

Company Name: Eversource Hoisting Equipment License Number: _____

Grade: _____ Expiration Date: _____

Contact Number: 508-441-5817 Name & Contact Number of Insurer: _____

Competent Person on Work Site: ON FILE

APPROVED BY: Stephen Cyprian DATE: 9-11-22
TITLE: Asst City Engineer

This permit shall be posted at the work site, and shall remain until the work is completed. It is subject to inspection at all times.

Work completed prior to D.P.I. approval under
emergency work order for Class II Leak

Trenches must be maintained
weekly until final paving is
completed

ROADWAY CLOSURES WILL REQUIRE
AUTHORIZATION FROM THE
COMMISSIONER OF PUBLIC
INFRASTRUCTURE. TRAFFIC MANAGEMENT
PLANS MAY BE REQUIRED.

Permit only valid for three months
from date of approval

DAILY ACTIVITY REPORT

EVERSOURCE

City/State/Zip
20221200733

Permit #
GAS-MLR0TH2Y

Project #
7822119-10-[RE70]

Work Order ID
7822119-10

Address
786 BELLEVILLE AVE

Town
NEW BEDFORD

Date
03/21/22

Order #
7822119-10

Task
GASMAINTENANCE

Contractor
WAMFWO: 30290541

Leak Class
WAMFTE # 887833

Work Type
GASMAINTENANCE

PIPE RETIREMENT

No

PIPE INSPECTION

FACILITY TYPE	MATERIAL TYPE	SIZE	EXT PIPE COND	INT PIPE COND	EXT CORR COND	INT CORR COND	COATING	DEPTH OF COVER
Main	Cast Iron	12	Fair	NA	Fair	NA	Fair	3'0"

PIPE INSTALL

FACILITY TYPE	MATERIAL TYPE	SIZE	LENGTH	PRESSURE	METHOD	OVERALL PIPE LENGTH	INSTALLED/REPLACED	DEPTH OF COVER	CONNECTION AT MAIN	EFV INSTALLED	EFV SUBTYPE	EFV COMMENTS
								0'0"				

PRESSURE TEST

No

RESTORATION

CONSTRUCTION MATERIAL	LOCATION	EXISTING SURFACE FINISH	EXISTING DEPTH	LENGTH	WIDTH	REQUIRED DEPTH	TEMPORARY REPAIR ACTION	COMPACTION METHOD	% COMPACTED
Hot Asphalt	Street	Asphalt	4	7'0"	5'0"	4"		DCP	100

MATERIALS

No

DESCRIPTION OF WORK COMPLETED

Repair leaking 12" bell joints

PERSONNEL

FOREMAN / WORKING LEADER / INSPECTOR

SIGNATURE

ClickMobile 2:31 PM Mon Mar 21

