

CITY OF NEW BEDFORD

APPLICATION FOR LAYING BUILDING SEWER AND/OR DRAIN SERVICE

Application No 20536

9/4/80
Date

To the Mayor and City Council:

I hereby request that a building sewer and/or drain be laid for the premises at East side MacArthur Drive, 50'± south of South Street

to connect with the sewer/drain in MacArthur Drive street, the same to be laid in the street and the surface repaired as directed by the Commissioner of Public Works.

I hereby agree to pay at the office of the City Treasurer all cost of performing the above work in the manner specified, in excess of the deposit made herewith, within 10 days after the completion of the work.

It is understood and agreed that the deposit made with this application shall be applied to the payment of the cost of performing the work done, and that any excess of deposit over the cost shall be returned to me by the City Treasurer.

Witness George D. Heath Inspector Beard Dartmouth Nova Scotia

Signature of Property Owner
Cape Building Systems Inc 7584596
Address W. John H. 11th Telephone No.
George D. Heath
Plumber's Name
North St. Mattapoisett
Address

Requires separate entrance for roof water

Permits to Industrial and/or Commercial Applicants:

Permits can be issued to industrial and/or commercial applicants only upon receipt by the Commissioner of Public Works of such supplemental information as may be required by him concerning the quality and quantity of the proposed wastewater discharge.

This information was submitted by John W. Fisher Jr. Pres agent for Owner
Signature of Applicant (owner)
and approved by the Commissioner of Public Works on 9/4/80
Date

George F. Brightman
Commissioner of Public Works ddl

Estimate and Deposit Requirement

Office of Commissioner of Public Works, 9/4/80
My estimate of the cost of laying the building sewer and/or drain described in the above application is

Assessed
Entrance charges Total deposit required \$15.00
George F. Brightman
Commissioner of Public Works ddl

Certificate of Issue

Office of City Clerk, 9/4/80
The above application, accompanied by City Treasurer's receipt presented this day; whereupon Permit No. 20536 was issued, and the Commissioner of Public Works notified of the same.

Grace A. Davidian
City Clerk ddl

Laid from main in street to property line.
Owner agrees to supply all necessary materials and transite pipe.

Insp. only - No S.D. Conn. S.D. CONN. TO C.B. ON E.S. MACARTHUR DR.
(Frank Linhares Cons.) S. OF SOUTH ST. 10-28-80
CAPE BUILDING SYSTEMS BONDED TO WORK ON CITY PROPERTY, LB.


8-15-80

Bill Bucher:

Plan appears OK
assuming the following

1. Parking lot drainage
to street.
2. Only domestic waste

Jack T.



TS

REVISED PLAN ATTACHED.

JACK TURNER,

8-11-80



8/4/80


Bill Boucher

What does the
penciled rectangle
represent?

No sewer lines, storm
lines, N arrow,
etc., title block, stamps.

Insufficient detail
REJECTED!

Jack T.



Permit No. 20536

JOHN FOLINO, JR.
758-4596

CITY OF NEW BEDFORD
DEPARTMENT OF PUBLIC WORKS

Supplementary Information Required from Commercial or Industrial Firms in Addition to Issuance of Sewer Entrance Permit

- A. Architect's floor plan showing proposed connections to building drain (inside building):
B. Architect's detail drawings of any pretreatment or equalization equipment:
C. Site plan showing:

- (1) Building and location of building sewer
(2) Proposed connection to public sewer
(3) Profile of building sewer
(4) Plan and profile of storm drain
(5) Location of control manhole
(Standard type — preferably between property line and public sewer.)

D. Wastewater Information:

Date: 7/24/80

- (1) Name of firm: IMP Fishing Gear Ltd
(2) Address: South St & MacArthur Drive New Bedford
(3) Name and title of person completing form. (company representative):
John W Folino Jr Pres, Cape Building Systems Inc.
(4) Industry type (SIC Number):
(5) Number of Employees: 5-10
(6) Principal products manufactured, produced, processed or sold: fish nets
(7) Sources of water supply: Municipal 100% Well
(8) Estimated volume of water to be used per day: 150 gallons.
(9) Flow gauges in plant none influent effluent.
(10) Water consumed in processes: none %.
(11) Recycled water: none %.
(12) Cooling water: none %.
(13) Number of operating days per week: 5
(14) Number of shifts per day: 1
(15) Type of discharge: continuous batch.
(16) If batch per shift.
(17) Estimated volume of wastewater discharged daily 150 gallons.
(18) Wastewater abatement practices to be used:
(a) Process changes: none
(b) Changes in raw materials: none
(c) Recycling methods: none
(d) Wastewater treatment equipment: none
(e) Monitoring devices: none
(f) Sampling and testing procedures: none

(19) Expected constituents of final wastewater discharge:

- | | | |
|----------------|-----------------|------|
| (a) pH | (d) Cl Req'm't. | mg/l |
| (b) Grease/Oil | (e) S. S. | mg/l |
| (c) C O D | (f) Color | mg/l |

(20)

Signature of Property Owner


Date

WASTEWATER DIVISION - D.P.W.
FORT RODMAN
NEW BEDFORD, MASS. 02744
8-15-80
JF

as agent

John W Folino Jr Pres

7/24/80



I. M. P. GROUP LIMITED

BOX 535
15 AKERLEY BLVD.

DARTMOUTH, NOVA SCOTIA, CANADA
B2Y 3Y6

HEAD OFFICE

TEL. 902-469-0222
TELEX: 019-31474

July 24/80


Mr. John W. Folino Jr.-PRESIDENT
Cape Building Systems, Inc.
Industrial Drive
Mattapoisett, Massachusetts
02739

Dear Mr. Folino:

In your capacity as the proposed builder, you are authorized to act on behalf of I.M.P. Group Limited and I.M.P. Fishing Gear, Inc. (to be incorporated) in order to secure necessary zoning variances, building permits, and utility contracts to enable construction of the company's new plant on lot 3A, South Terminal, New Bedford, Mass.

Should any individuals require confirmation of this document they may contact me in writing or phone at (902) 469-0222. Trusting this will enable you to secure the approvals you require.

Sincerely,



P.Y. Hunter
Corporate Administrator

PY/lc

