

PERMIT NO. 22372

Date 9-6-95

Location of premises SO. FIRST ST. (E.S.) 83' ± N/BLACKMER ST.

Assessors' Plot 25, Lot 12

Property Owner NB HOUSING AUTHORITY 725 PLEASANT ST. NB. MA. 02740.

Contractor or Drain Layer J.S. LUZ 3rd INC. 12 VENTURA DRIVE NO. DARTMOUTH MA-02743

Connection made to ☒ Sanitary Sewer in SO. FIRST ST.
* ☒ Storm Drain Street

Part of jointly - shared private line ☐ Yes ☒ No

Type of Pipe required PVC SDR 35

Other conditions INSP ONLY - TO BE CONNECTED TO A DEAD END SMH IN

THE E OF STREET - 2310 GPD.

31-143 * ALL WELLS MAY GET SUBSTITUTED W/ DPW APPROVAL

Service installed by J.S. LOIZ III

Inspected By Joseph Lantz Date 3/21/96

Inspection Results	Pass	Fail	Reason
Pipe Slope	☒	☐	
Pipe Allignment	☒	☐	
Pipe Joints	☒	☐	
Pipe Bedding	☒	☐	
Backfill	☐	☐	
Compaction	☐	☐	

As - built sketch rec'd. ☒ Yes ☐ No

Date 6-17-96 ID