

PERMIT NO. 22404

Date 12/19/95

Location of premises sec Chaffee St^(SS) and Windover St

Assessors' Plot 130.C., Lot 25

Property Owner William Richards 1068 Chaffee St. N.B. 02745
Name Address

Contractor or Drain Layer Reis Asphalt 996-0735

Connection made to ☒ Sanitary Sewer in Chaffee Street
☒ Storm Drain StreetPart of jointly - shared private line ☐ Yes ☒ No

Type of Pipe required pvc. sdr - 3.5

Other conditions INSP. ONLY - TO BE CONNECTED TO 10" Sewer
& 10" SURF-Drain - 330 GPD.

Service installed by REIS ASPHALT

Inspected By Joseph Spata Date 4/11/96

Inspection Results	Pass	Fail	Reason
Pipe Slope	☒	☐	
Pipe Allignment	☒	☐	
Pipe Joints	☒	☐	
Pipe Bedding	☒	☐	
Backfill	☐	☐	
Compaction	☐	☐	

As - built sketch rec'd. ☒ Yes ☐ No

Date 9-6-96 OK IS.