

PERMIT NO.



CITY OF NEW BEDFORD

DATE 8/2/02
EXP 8/2/03

23267 EXT

SEWER AND/OR STORM DRAIN PERMIT

This certifies that permission is granted to

Wayland Development Corp. 867 Middle Rd. Acushnet MA 02743
Property Owner Address Tel. (508) 763-8868

to connect a sewer and/or storm drain located at Woodford Estates Subdivision - Off Phillips Rd.
Assessor's Plot 132, Lot 374, 21, 479, to the sewer and/or storm drain in. Stephanie's Place; Erin's Court
to be laid in accordance with the conditions in this application and the City of New Bedford ordinances. Street

TYPE OF USE: ☐ RESIDENTIAL ☐ COMMERCIAL ☐ INDUSTRIAL ☒ OTHER
If applicant other than actual property owner, attach Letter of Authorization from Property Owner. Sewer Main & Storm Drain Extension System/Manhole Extension

Name N/A Tel.

Mailing Address

The Bonded Contractor/Drain Layer authorized to perform this work is:

D.W. White (508) 763-8868
Name Address Tel.

Type of Pipe Required: PVC SDR 35 - See attached plans & attached DEP Special Conditions.

PERMIT EXPIRES ONE YEAR AFTER DATE OF ISSUE

- * Requires separate connections for sewage and storm drain where applicable. Storm water cannot be discharged to a sanitary sewer.
- * All work must be inspected and approved by a D.P.W. inspector before backfilling.
- * If this connection is to be part of a private service shared jointly with other building owners, attach copy of Recorded Joint Maintenance Agreement.
- * Permits can be issued to Industrial and/or Commercial Applicants only upon receipt and approval by the Commissioner of Public Works of required plans and supplemental information.
- * In addition, a City-issued Industrial User Discharge Permit and/or a Sewer Extension/Connection Permit issued by the Commonwealth of Massachusetts D.E.P. shall be required by the City for Industrial Discharge into the sewer system.

Industrial User Discharge Permit No. Date
Comm. Mass. Sewer Conn./Ext. Permit No. W027667 Date 7/23/02

A Filing and Inspection Fee of \$150.00, plus an Entrance Fee of \$6474.00 where applicable, must accompany this application.

Bank # Compass Bank Check # 639 Date: 8/2/02 Receipt # 4383

Other requirements: Inspection Only - Woodford Estates Subdivision - Stephanie's Place 881' x 2.1ft; Erin's Court 510' x 2.1ft; Lauren Drive 912' x 2.1ft; Katelyn's Way 794' x 2.1ft and plus \$150.00 Permit Fee Total = \$6624.00

Connection made to ☒ Sewer ☒ Storm Drain Part of jointly-shared private line ☐ Yes ☒ No

Per Larry Worden, no fee for storm drain system/main extensions.

Applicant agrees to abide by the above terms, as well as all pertinent ordinances of the City of New Bedford, and such other special rules as the Commissioner of Public Works may deem necessary

Lawrence D. Worden
Commissioner of Public Works

Signature of Property Owner or Representative

INSPECTOR'S REPORT

INSPECTED BY:

DATE:

COMMENTS:

☐ APPROVED ☐ DISAPPROVED

SIGNATURE

SKETCH PLAN

PERMIT NO.

23267 EXT



CITY OF NEW BEDFORD

DATE 8/2/02
EXP 8/2/03

SEWER AND/OR STORM DRAIN PERMIT

This certifies that permission is granted to

Wayland Development Corp. 867 Middle Rd. Acushnet MA 02743

Property Owner

Address

Woodford Estates Subdivision - 014 Phillips Rd.

Tel. (508) 763-8868

to connect a sewer and/or storm drain located at contemplated Stephanie's Place; Jennifer's Lane;
Assessor's Plot 132, Lot 374, 21, Lauren Drive; Katelyn's Way; Erin's Court
to the sewer and/or storm drain in contemplated Stephanie's Place; Street
Jennifer's Lane; Lauren Drive; Katelyn's Way;
to be laid in accordance with the conditions in this application and the City of New Bedford ordinances. Erin's Court

TYPE OF USE: ☐ RESIDENTIAL ☐ COMMERCIAL ☐ INDUSTRIAL ☒ OTHER Sewer Main & Storm Drain Extension System/Manholes Extension

If applicant other than actual property owner, attach Letter of Authorization from Property Owner.

Name N/A Tel. _____

Mailing Address _____

The Bonded Contractor/Drain Layer authorized to perform this work is:

D.W. White

(508) 763-8868

Name

Address

Tel.

Type of Pipe Required: PVC SDR 35 - See attached plans & attached DEP
PERMIT EXPIRES ONE YEAR AFTER DATE OF ISSUE Special Conditions

- * Requires separate connections for sewage and storm drain where applicable. Storm water cannot be discharged to a sanitary sewer.
- * All work must be inspected and approved by a D.P.W. inspector before backfilling.
- * If this connection is to be part of a private service shared jointly with other building owners, attach copy of Recorded Joint Maintenance Agreement.
- * Permits can be issued to Industrial and/or Commercial Applicants only upon receipt and approval by the Commissioner of Public Works of required plans and supplemental information.
- * In addition, a City-issued Industrial User Discharge Permit and/or a Sewer Extension/Connection Permit issued by the Commonwealth of Massachusetts D.E.P. shall be required by the City for Industrial Discharge into the sewer system.

Industrial User Discharge Permit No. _____ Date _____

Comm. Mass. Sewer Conn./Ext. Permit No. W027667 Date 7/28/02

A Filing and Inspection Fee of \$150.00, plus an Entrance Fee of \$6474.00 where applicable, must accompany this application.

Bank # Compass Bank Check # 639 Date: 8/2/02 Receipt # 4383

Other requirements: Inspection Only - Woodford Estates Subdivision - Stephanie's Place 881' x 2.1ft;
Jennifer's Lane 140' x 2.1ft; Lauren Drive 912' x 2.1ft; Katelyn's Way 794' x 2.1ft and
Erin's Court 510' x 2.1ft, plus \$150.00 Permit Fee Total = \$6624.00

Connection made to ☒ Sewer Part of jointly-shared private line ☐ Yes ☒ No

☒ Storm Drain

Per Larry Worden, no fee for storm drain system/manholes extensions.

Applicant agrees to abide by the above terms, as well as all pertinent ordinances of the City of New Bedford, and such other special rules as the Commissioner of Public Works may deem necessary.

Larry D. Worden, Jr.
Commissioner of Public Works

[Signature]
Signature of Property Owner or Representative

INSPECTOR'S REPORT

INSPECTED BY: _____

DATE: _____

COMMENTS: _____

☐ APPROVED

☐ DISAPPROVED

SIGNATURE

SKETCH PLAN

Permit No. W027667
NEW BEDFORD

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER POLLUTION CONTROL**

(21) SPECIAL CONDITIONS

1. Sewer line and water main separation shall conform to guidelines in TR-16, Guides for the Design of Wastewater Treatment Works, 1998 Edition;
2. Manholes shall be designed for watertightness if located in areas subject to flooding and for any anticipated loadings;
3. All sewer piping material shall be a minimum of schedule 35 PVC pipe;
4. Drop type manholes shall be provided for sewers entering manholes with elevations of 24 inches or more above the manhole invert;
5. All sewer piping and structures crossing, or within the buffer zone (100 feet) of, any wetlands or surface water bodies or impoundments shall be built using watertight construction methods;
6. The permittee shall seek and obtain local conservation commission approval prior to construction of this sewer.

END OF SPECIAL CONDITIONS