

Relay
filled spot
162 INUBST
28
CLEARING DRAIN

New Bedford

19

Application No.

6254

Time

3:15 P.M.

I hereby request you to clear drain at premises

966 Wildwood Rd.

has to be dug up; dug up complete relay job
RELAY JOB COMPLETE, BAD CONNECTION AT SEWER, CITY
AT FAULT

And I hereby agree to pay at the office of the City Treasurer all cost of performing the above work.

Relay - no charge *(B)*

Witness

Applicant

Frank Josefek
If telephoned, message taken by

Had Rotorator

(To Thurs. A.M.)

Roll 27 - 9.77
Roll 28 - 119.89

RETURN OF FOREMAN

Entered July-3RD 1969
Time JULY 7, 8, 9
By John A. Law

Joseph A. Thibault
COST
Labor 1/3: Law, J - 1 hr @ 265
Ferreira - 1 hr @ 232
Orlowski - 1 hr @ 250
De Cicco - 1 hr @ 250
\$9.97 - INV.

7/7, 7/8, 7/9
Law, J - 2 hrs @ 265 = \$530
Ferreira - 9 hrs @ 232 = 2093
Orlowski - 12 hrs @ 250 = 3000
Paiya, A - 2 hrs @ 240 = 480
De Cicco - 2 hrs @ 250 = 500
Thibault - 6 hrs @ 265 = 1590
Arroyave - 10 hrs @ 232 = 2325
De Cicco - 6 hrs @ 246 = \$14.71
Stock
100 LB. SAND
1 BAG CEMENT
\$119.89 - Relay

used Cleo Roster

2 HA Trucking T.R. 25
2 HA #81-TRUCK
4 HA #33 BACKHOE BACKHOE 33
1 HA. COMP. 21

Total Cost
Deposit \$25.00 7/3/69
Balance Due

Pieces pipe to curb 2-10'-6 IN PIPE
" " curb to house 3-10' 6 IN PIPE
Cut at Sewer 7 1/2 FT.
Cut at Curb 6 1/2 FT.
Size of pipe 6 IN. TRANSITE
Correct

John A. Law
Foreman
Joseph A. Thibault

2011 11/11/11 11/11/11