

Factory.

Bldg. rates, no charge.

By Joseph Hewett, Secy.

6" ser.

Fire Supply. NEW BEDFORD WATER WORKS.

SERVICE PIPE RETURN.

No. 13403

*2 inch pipe
connected inside
of factory
Requires 2 in
meter*

For E. E. Taylor Co.,

No. E. S. Acushnet Ave., S. of North

Street.

The expense for labor and materials to be paid
by the applicant is as follows:

lineal feet of earth excavated at	cents per foot,		
lineal feet of rock excavated at	cents per foot,		
11.2 lineal feet of inch lead pipe at	cents per foot,		
11.3 lineal feet of 6 inch ^{cast} iron pipe at	50 cents per foot,	56	50 -
lineal feet of inch tin lined pipe at	cents per foot,		
1-3W 12x12x6 branch	470 lbs.	1-6" Chap. bell gate	15 20 -
1-3W 6x6x6 "	230 "	310 lbs. lead @ 5/44	16 28 -
1-12 in. disc	180 "	13 lbs. gasket @ 5/44	0 75 -
2-6 " 1/4 turn	28.7 "	Labor 77.69; city 5.50	83 19 -
2-6 " 1/8 "	212 "	Fireman & team - 1 day @ 8.00	8 00 -
1-6 " iron gate bx	233 "		
1-6 " plug	17 "		
	1754 lbs. @ 3¢ -		52 62
Proportion of other expenses for putting services into premises			
Amount		\$	232 54 [®]

✓ Bill 2 in Meter,
ask Mr Wilbur for
kind of meter set,
Bill 2" Lambert
meter with fishtrap.

Office of Superintendent,

June 15th, 1910.

R. B. P. Boggesshall Superintendent.

WATER REGISTRAR'S OFFICE.

May 21, 1910. 19

To the Superintendent of the New Bedford Water Works:

Please put in a Service upon the premises described above, and make
return of the expense of the same to this office.

E. Baylies Water Registrar.
per W. P.

16
24

appli. #13403
E. S. Ac. Av. S. of North st.
E. E. Taylor Co.