

Feb. 28, 1948

#22533

Minit Auto Wash, Inc.
E.S. Acushnet Ave., N x Willis St.

Please install $1\frac{1}{2}$ " City Meter &
2" Copper Service to supply auto laundry.
To tap main with 2- $1\frac{1}{4}$ " copper leading into
2" copper.

MIA. - OF 2" gate valve -
SxS Line Pearl St.
WxE " Acushnet Ave.
SxN " House

146.0

5.2

2.3

No cuts

Laid 3-17-1948

(over)

30' of 2" cop. type K

7' of 1 1/4" cop. " "

2-2" brass caulking nipples = ^{For cop.} \$4.00

1-2" cop. to cop. coupling

2-1 1/4" cop. to Iron couplings Fig. 413

2-1 1/4" corporations For cop. Fig. 438

1-2" Dan gate valve All bell

1-4" Caldwell gate box

12 Lbs. caulking Lead

1 Lb. gaskets

caulking

5.00

Use of compressor

12.00

Labor

52.42