

June 3, 1948.

#22594 George H. Philpott
N. S. Bowles St., W. x Acushnet Ave.

Please install $3/4$ " City Meter and
 $3/4$ " Copper Service to supply cottage.
~~Trench to be dug by taker.~~

W x W	Line	Acushnet Ave.	320.4
S x N	"	Bowles St.	6.3
W x E	"	House	2.0

Oct. 19, 1960 - the $3/4$ " Hall Thread was returned to
the repair shop. A reinforced thread corporation was
installed into the newly installed main pipe in Bowles
in line with the stop box.

Laid 7-26-1948

53 Ft. of $\frac{3}{4}$ " cop. typēk

1- $\frac{3}{4}$ " corporation Fig. 438 with nut

1- $\frac{3}{4}$ " cop. to cop. stop Fig. 415

1-stop box (complete)

Casting = \$ 2.00

50 Ft. trenching = 37.50

Service Repaired

October 18, 1960

N. S. Bowles St., W x Acushnet Ave. 320.4 ft.

Service #22594 was disconnected from the hydrant tee plug and reconnected into the newly installed main pipe. The Hall Thread corporation was returned to the repair shop. The Reinforced thread corporation is in line with the stop box.

1-3/4" corporation, fig. 438 - R. H. Reinforced thread

Langlois

Lownds

