

Oct. 20, 1948

#22715 Massachusetts Air Industries
W.S. Shawmut Ave., S. of Plainville
Rd.

Please install 6" Fire Supply to
supply airport hangar. Taps 8" main in
Shawmut Ave., to be increased to 12" from
tapping gate to inside of building. (6"
tapping gate). *met. of 6" gate -*

<i>MX Last Hyd., SX Plainville Rd.</i>	<i>19.4</i>
<i>Ex W Line Shawmut Ave.</i>	<i>29.2</i>
<i>SKN " Bldg.</i>	<i>85.0</i>

Work done Oct. 21-1948

18 ft of 12" Delavan P.P. = \$90.00

1-6" Dr. trap gate = 54.84

1-8x8x6" trap sleeve = 42.50

1-8" c.t. gate box (complete) = 44.10

1-6" to 12" X-H C.T. Invertor. B. = 25.00

17" Land. ite = 2.55

1" gasket =

Carrying = 6.00

Use of w/o - frame = 14.00

Labor = 83.49