

9-6

Nov. 30, 1949

#23005

N.B. Housing Authority
S.S. Newcombe St., E x Mt.
Pleasant St.

Please install 3" Taker's Meter
& 3" copper service to supply housing units.

work done Dec. 16-1949 not completed-
services to be completed when main is laid.

Dec. 28, 1965: Recaulked a leaking (Over)
East bell joint of 8"x8"x4" tee - see report

72'6" of 3" copper tubing type K	-----	
1-3" Darling gate valve (all ball)	-----	
1-R-144 Caldwell gate box	-----	
1-3" cop. to cop. 90° elbow A-1781	-----	
2-3" cop. to hub calking connection A-7163	-----	
3-3" cop. to cop. couplings A-1775	-----	
1-3" x 1 1/2" cop. to cop. reducing coupling	-----	
1-1 1/2" x 1" fitting to cop. bushing A-1668	-----	
Use of Moto-Grane	-----	24.50
Carting	-----	4.50
Labor <i>not including 15%</i>	-----	52.80

9-6

#23005

N.B. Housing Authority

3"

S.S. Newcomb st., E x Mt. Pleasant St.

12 ft. of 3" copper tubing type K

1-4" x 3" Hub to cop. connection A-7169

1-3" cop. to cop. coupling A-1775

1-8x8x~~1/2~~ Branch all bell B.

10# Leadite

8# Calking lead

1~~1/2~~# Gasket

Labor

Plumber's bill (Coholan)

26.40

18.00

Mea. 3" gate valve

Work done May 1 & 2 - 1950

Now completed.

Regular service charge
do not charge out.

