

Sept. 29, 1950

#23318


Albert Benjamin

W.B. Ball St., N x Darling St.

Please install 3/4" City Meter
& 3/4" Copper service to supply bungalow.
~~Main to be extended as far as street is~~
~~accepted, or approx. 50' lay in drain. trench~~
on taker's land.

47-46--Laid with drain-60' of 1" cop.	\$26.40-lab. \$1.00
N x N line Darling St.	19.6
E x W " Ball St.	4.6
S x S " House	14.7
1 st. out 15' x 2 1/2' - Tar	
Work done Oct. 9, 1950	(OVER)

Tap in hydrant pipe 4 ft. east from the center of hydrant.



Service Repaired
17 Ball Street

April 14, 1955

Service #23318 - $3/4"$ was repaired when the 21' of $3/4"$ copper tubing WERE removed from the hydrant pipe opposite Darling St., The $3/4"$ tap was also removed and relocated to the 6" C. I. main installed on Morris & Ball Sts. from Ludlow St. to Darling St. - in line with the curb stop for this service. A $3/4"$ tapered plug was installed into the hydrant pipe.

New measures of Curb stop:

N x N line Darling Street	19.4
E x W " Ball Street	7.2
S x S " house	14.1

Work done April 14, 1955

(over for sketch)

