

Dec. 11, 1950

#23368

Hilda Hayes  
N.E. Cor. #670 County St.,  
x Campbell St.

Please install 6" Cast Iron  
Fire Supply service to supply convalescent  
home.

Measure of 6" Tapping Gate Valve:

|                       |      |
|-----------------------|------|
| E x E Line County St. | 57.7 |
| N x S " Campbell St.  | 15.0 |
| E x E " Building      | 2.8  |

Work done Dec. 13, 14, 15, 1950

|                                                         |        |
|---------------------------------------------------------|--------|
| 79 ft. of 6" C. I. War. Spun Cem. Lin. Pipe             |        |
| 1-6" Tapping Gate - Darling                             |        |
| 1-6" x 6" x 6" Tapping Sleeve- A. F. S.                 |        |
| 1-6" C. I. Gate Box - Complete                          |        |
| 1-6" Offset-12" cen. to cen., Bell & Spigot             |        |
| 1-6" $\frac{1}{2}$ Bend-Bell & Spigot, Builders         |        |
| 1-6" $\frac{1}{2}$ Bend-Flange & Spigot, 72" Long - (B) |        |
| 1-6" Single Strap                                       | 5.00   |
| 1 Street cut: 13' x 3' Pen. Mac.                        |        |
| 1 Sidewalk cuts: 7' x 2' Cement                         |        |
| 129 Lbs. of Caulking Lead                               |        |
| 5 Lbs. of Gasket                                        |        |
| Use of Tapping Machine                                  | 10.00  |
| Use of Compressor                                       | 30.00  |
| Carting                                                 | 15.00  |
| Labor                                                   | 153.30 |

Offset is located in middle of sidewalk