

June 11, 1952

125C
125

#23757 Helen Gudewicz

N.S. #875 Plainville Rd at Mt. Pleasant
Please install 6" Fire Supply for Convalescent
Home. To tap hydrant branch if possible.

Meas. of 6" Fire Supply Gate:

E x E Line Mt. Pleasant St.	39.0
S x E " Plainville Rd	14.0
E x E " House	12.0

Meas. of 6" Fire Main Service Gates:

E x E Line Mt. Pleasant	195.0
S x N " Plainville Rd.	3.3

~~Meas. of 6" Hydrant Gate:~~

E x E Line Mt. Pleasant St.	201.3
S x N " Plainville Rd.	3.3
E x Center Hydrant	2.9

(OVER)

Work done June 16, 17, 18, 1952

220' of 6" C. I. War. Spun Co. Line Pipe.....	
2-6" Gate Valve, All Bell-Working.....	
2-6" C. I. Gate Boxes, complete.....	
1-2 1/2" C. I. Round Gate Box Riser.....	
1-6" x 6" x 6" Tee, All Bell-Builders.....	
1-6" x 6" x 6" Tee, All Bell-W. W. E.....	
1-6" C. I. Plug, tapped 1 1/2".....	5.17
1-6" Single Pipe Strap.....	5.00
1-6" Bend, Bell & Spigot (17 1/2" Long) Builders..	
1-6" Bend 6' Long, Flange & Spitot-Builders..	
66 Lbs. Leadite.....	
4 Lbs. Gasket.....	
Carting.....	20.00
	65.00
Moto-Crane Trench Hoe.....	16.00
Use of Bull-dozor.....	25.00
Supervision.....	
Labor.....	\$161.17