

Sept. 28, 1953

#24157 James H. Mahoney Jr.
W.S. Ash St., S x Moreland Terr.

Please install 2" City Meter &
2" Copper service to supply garage. Ser. to
box on taker's land. From Ash St.

Meas. of 2" tapping gate valve-

N x S Line Grove St. 21.0

E x W " Ash St. 11.0

16" is on a 12' Line at this point.

Work done Oct. 1 & 2 --1953

OVER

\$28.88

16'6" of 2" copper tubing type K

1-16x16x2 tapping sleeve V.P.S.

1-2" Darling tapping gate valve

1-4" C.I. gate box-complete

1-2" cop. to hub caulking conn. A-7086

16# Leadite

2# Caulking lead

1# Braided jute

Use of compressor

" " tapping machine

1-Street cut 8'x 7' Pen. Mac.

Caulking

Labor

Supervision

25:22

88.82

8.00

5.00

18.00