

Ext. with 2" copper from the property line to inside
building. 8 ft. supplied & installed by taker's plumber
July 15, 1955

#24560 Dept. of Public Works (City of N.B.)
E.S. #1340 Rod. Fr. Blvd. (E), Foot of
Apponegansett St.

Please install 2" City Meter & 2"
Copper service to supply sewerage disposal
station. Taps Rod. Fr. E & D.P.W. to do work.
Replaces 1" Ser. #21612.

Measure of 2" gate:

S x N line	Apponegansett Street	28.1
W x E "	Rodney French Blvd. (E)	13.0
N x S "	Building	9.0

Work done October 26 & 27, 1955

(over)

54 ft. of 2" copper tubing type K, soft.....	\$116.64
1 ft. of 1" " " " " "	.90
1-2" Gate Valve, all bell - Darling.....	
1-2" Corporation #1200 - Welsbach.....	
2-2" cop. to hub caulk. conns., A-7086.....	
2-2" cop. to cop. cplgs., A-1671.....	
1-2" x 1" cop. reducing cplg., A-1716.....	
1 Mueller service clamp, 12" x 2".....	
8 lbs. caulking lead.....	
1/2 lb. braided jute.....	
1 lb. wiping solder.....	
1 B-144 Caldwell valve box.....	
Use of tapping machine.....	5.--
Use of compressor.....	18.--
2 street cuts: 7' x 2½' & 5' x 3' Warrenite....	
Carting.....	5.--
Supervision.....	22.44
Labor.....	90.89