

Aug. 31, 1955

#24629

N.B. Fire Dept.

N.W. Cor. Acushnet Ave. & Holbrook St.

Please install 2" Taker's Meter &
2" Copper service to supply fire barn. To
street line only.

Mea. of 2" Gate Valve:

W x W line	Acushnet Avenue	155.5
S x N	" Holbrook Street	8.0
E x W	" Building	15.8

Work done May 9, 1956

(over)

31½ ft. of 2" copper tubing type K, soft.....	76.55
1-6"x6"x¼" tee, All Bell, - Builders.....	
1-2" Gate Valve, All Bell - Darling.....	
2-2" cop. to cop. cplgs., (wrot) - A-1671.....	
2-2" Cop. to hub caulk. conns., A-7086.....	
1-2" cop. x 2" Out. I. P. S. cplg., A-1672...	
1-4" C. I. plug tapped 2".....	4.68
1 R-144 Caldwell gatebox.....	
Use of motocrane.....	7.--
9 lbs. lead.....	
2 lbs. leadite.....	
1/2 lb. braided jute.....	
Carting.....	5.--
Supervision.....	3.74
Labor.....	24.48

The owner supplied & installed 60 ft. of 2"
 *copper from the property line to inside the building.