

Nov. 9, 1955

#24708-C Wood Development Corp.
N.E. Cor. Tarkiln Hill Rd., &
Lambert St.

Please install 2" City Meter &
2" Copper service to supply our plant. 2"
conn. of 8" Fire Supply #24707, taps in
street.

Measure of 2" Gate:

E x E	line Lambert Street	13.3
S x N	" Tarkiln Hill Road	5.9
E x W	" Building	2.2

Work done November 28, 29, & 30, 1955

(over)

30 ft. of 2" copper tubing type K, soft.....	67.20
1-2" cop. to cop. cplg., A-1671.....	
1-2" cop. to cōpt. elbow, 90°, A-1677.....	
1-4" x 2" cop. to fitt. reducing bush., A-1939.....	
1-2" Gate valve, all bell - Darling.....	
1 R-144 Caldwell gate valve box.....	
2-2" Copper to hub caulk. conn., A-7086.....	
8½ lbs. caulk. lead	
1/4 lb. braided jute.....	
2 lbs. leadite.....	
Use of motocrane.....	77.--
1-4" cop. to hub caulk. conn., A-7220.....	
Use of compressor.....	24.00
Carting.....	15.--
Supervision.....	44.88
Labor.....	\$303.94

Compressor, motocrane, carting, supervision & labor charges for Ser. #24707 are included in this service card. Both services were laid in the same trench.