

July 1, 1957

164 Riverside  
Drive  
Tiverton, R. I.

#25206

Harbor Development Corp.

CAPE ST. N.S. Howland, 20' right of way, E X  
~~Prospect St.~~

Please install 2" City Meter & 2"  
copper service to supply freezer. Replaces  
#20805 to be discontinued. Box on taker's land.

Measure of 2" Gate Valve:

|                             |       |
|-----------------------------|-------|
| E x E line Cape Street      | 533.7 |
| S x N Howland St. (20' Way) | 10.8  |
| E x W " Meter Box           | 1.8   |

Service laid to meter box

Work done July 8 & 9, 1957

(over)

|                                              |          |
|----------------------------------------------|----------|
| 20 ft. of 2" copper tubing type K, soft..... | \$ 32.40 |
| Labor.....                                   | 58.80    |
| 1-2" Tapping gate valve - Darling.....       |          |
| 1-8"x8"x2" tapping sleeve - A. F. Smith..... |          |
| 1-4" C. I. gate box, complete.....           |          |
| 1-2" Cop. to hub Caulk, Conn., A-7086.....   |          |
| Carting.....                                 | 2.—      |
| Tapping machine use.....                     | 9.—      |
| Compressor use.....                          | 9.—      |
| 4½ lbs. caulking lead.....                   |          |
| 8 lbs. leadite.....                          |          |
| ¾ lb. braided jute.....                      |          |
| 1 street cut: 10' x 2½' Warrenite.....       |          |
| Supervision.....                             | \$ 16.70 |

Additional Measures

March 6, 1991

N.S. Howland 20' Right of Way  
E x Cape St.

Ser. # 25206 2"

Directly west - in line with hyd. gate 8.0 ft.

N x curb 4.5 ft.

E x Cape S t. 44.0 ft.

JR

