

Nov. 26, 1957

c/o Ernest Margeson
1651 Purchase
St.

#25317 Immaculate Conception School
N.S. Davis St., W x Diman St.

Please install 3" Takers Meter & 3"
Copper service to supply school bldg. ~~Box~~
~~on taker's land.~~ Lay with drain.

To property line only

Measure of 3" Gate Valve:

W x W line Diman Street	208.4
S x N " Davis Street	31.3
W x E " Foundation	44.4

Laid with drain - Main is 12 ft. S x N line
Work done December 13, 1957

(over)

32½ ft. of 3" copper tubing type K, soft.....	\$ 94.90
Labor.....	\$ 59.76
1-3" Tapping Gate Valve.-Darling.....	\$
1-6"x6"x3" tapping sleeve - A. P. Smith.....	\$
1-4" C. I. gate box, complete.-.209lbs.....	\$
2-4" C. I. round risers.....	\$
1-3" Cop. to hub caulk. conn., A-7163.XH.....	\$ 9.90
1-3" cop. to cop. cplg., A-1775.....	\$
1-3" cop. to cop. cplg., A-4306.....	\$
Compressor use.....	\$ 9.--
29 lbs. caulking lead.....	\$
2 lbs. braided jute.....	\$
Tapping machine use.....	\$ 10.--
Carting.....	\$ 5.--
1 street cut: 6' x 2' Warrenite.....	\$
Supervision.....	\$ 2.09