

PLAN

124

Pagani Bros.Const.Co.
So.Main St.W.Bridgewater

July 18, 1958

#25406-C National Guard Armory
S.S.Tarkiln Hill Rd., E x Mt.
Pleasant St.

Please install 2" Meter & 2"
Copper service to supply maintenance depot.
2" connection of Ser.#21983.

Mea. of 2" tapping gate valve:

S x Chain link fence	47.3
E x E Line Bldg.	32.2
N x N " "	8.5

Work done Aug. 18, 1958

(OVER)

ABANDONED - ATE 140
IN PLACE - 11-23-70

1-8"x 8"x 2" <i>tapping</i> sleeve.....	A.P. Smith.....	\$
1-2" Dar. tapping gate valve.....		\$
1-R-144 Caldwell gate box.....		\$
26# Caulking lead.....		\$
1# Braided jute.....		\$
Use of Tapping machine.....		\$ 9.00
Use of compressor.....		\$ 1.50
Carting.....		\$ 5.00
Labor.....		\$ 32.04

40 ft. of 2" copper tubing type K, soft supplied
by National Guard Armory from the 2" Darling
tapping gate valve to inside