

c/o T. Loranger & Sons, 404 Nash Rd.

Sept. 22, 1959

#25624

J. Curry Mendes, Corp.

N.S. Braley Rd., Ext., W x Braley Rd.

Please install 6" C.I. Fire Supply to
supply manufacturing plant.

Measure of 6" Tapping Gate Valve:

W x 2nd hydrant W x Phillips Rd.	59.8
----------------------------------	------

W x W line Building	8.2
---------------------	-----

S x S " Building	127.0
------------------	-------

Work done September 23, 24, and 25, 1959 (over)
Owner's plumber supplied & installed 91 ft. of 6" C. I.
pipe from a point 12 ft. inside property line to inside
the building. (see sketch)

Noted use
85' 8 ft. of 6" c. i. cement lined pipe
Labor
1-16"x16"x6" Lapping sleeve - V. F. Smith
1-6" Stuffing Box Tapping Gate - Darling
1-6" 1/8 bend, Bell & Spigot, Com. Lin. - B. P.
1-6" 1/8 bend, Bell & Bell, Com. Lin. - B. P.
1-6" c. i. Gate Box, complete - 232 lbs.
76 1/2 lbs. Leadite
3 lbs. braided jute
2-3" c. i. round gate box risers
1-3" " " "
1-2" " " "
7-6" single Pipe Straps plus rods & washers
Cutting
Tubing machine use
Compressor use
Ladder use
Superdivision
1 street cut: 60' x 21' materials

120.39

27-50

16" main

TRIPPING SLEEVES

PROPERTY

LING

SKETCH FOR SERVICES # 25624 + # 25592.

1/8 BENDS - SIDE VIEW

85° 18' 40" N

25624

TAPPING GATES

→ -73 of 4 C.I.

4"x3" REDUCER.
#25592

25592

4040, 2010 + 0.6

1. The first step is to identify the problem or question that needs to be answered. This involves understanding the context and the specific information required.

3/2-073

12

27 1/2

打

BUILDING

2. 131A

2

N

