

10 Harvard St.

December 4, 1959

#25671

Arnold R. Briden

S. S. Nauset St. E. x Mt. Pleasant

Please install 2" City Meter and 2" Copper Service to supply (4) stores. Will notify when ready. To lot line only from Nauset St.

Measure of 2" A. B. Gate Valve:

E x E line Mt. Pleasant St. 168.6

S x N " Jefferson St. 6.7

Work done March 15, 1960

Main is 32 ft. S x N line

(over)

40 ft. of 2" copper tubing type K, soft.....	\$ 74.40
Labor.....	\$ 19.80
1 R-144 Caldwell Valve Box.....	\$
1 extension section for R-144 Caldwell Box....	\$
Carting.....	\$ 2.--
Motocrane use.....	\$ 14.--
Loader use.....	\$ 7.--
1-2" Darling A. B. Gate Valve - O-ring.....	\$
2-2" Cop. to Hub caulk. Conns., X heavy.....	\$ 10.62
1-2" Cop. to 4" hub caulk. conn.....	\$ 3.69
1-2" Cop. to cop. cplg., A-1671.....	\$
1-6"x6"x4" A. B. tee - W. W. E. 180 lbs.....	\$
17 lbs. caulking lead.....	\$
1 lb. braided jute.....	\$
Supervision	\$ 4.31