

November 19, 1959

TEL. No.: 7-8441

#25676

Odette R. Spadafora

N. S. #9 Pope St., W x Pleasant St.

Please install 6" C. I. C. L. Fire
Supply Service to supply nursing home. To street
line only.

Measure of 6" Tapping Gate Valve:

W x W line Pleasant Street	111.5
N x S " Pope Street	16.3
E x E " Building	5.4

Main is 26 ft. S x N line

Work done November 23, 24 & 27, 1959

(over)

23 ft. of 6" Cast iron cement lined pipe.....	
Labor.....	139.44
1-6"x6"x6" Tapping Sleeve - A. P. Smith.....	
1-6" Tapping Gate Valve - Darling.....	
1-6" C. I. gate box, complete, 224 lbs.....	
1-6" Offset, cement lined - 6" Offset C. B. P.....	
Carting.....	15.--
Tapping machine use.....	12.--
15 lbs. leadite.....	
1 lb. braided jute.....	
Compressor use.....	15.--
1 street cut: 10' x 3' Merrenite.....	
1 sidewalk: 4' x 2' Cement.....	
Supervision.....	34.51