

Tel: 6-2290

367 Sawyer St.

October 6, 1960

#25833

John Zychowicz

E.S. Lafayette St., N x Brooklawn
Ave.

Please install 1" City Meter & 1"
Copper service to supply bungalow. On exist-
ing main. 50¢ AGREEMENT. Lay with drain

Measure of 1" Stop:

N x N line Brooklawn Avenue

204.4

W x E " Lafayette Street

7.5

S x N " House

5.1

Laid with drain

Main is 32 ft. W x E line

Work done October 28, 1960

(over)

60 ft. of 1" copper tubing type K, soft.....	\$ 46.20
Labor.....	\$ 25.44
1-1" corporation, fig. 438 - Red Hed.....	\$
1-1" cop. to cop. stop, fig. 415 - Red Hed.....	\$
1 C. I. stop box, complete.....	\$
Carting.....	\$ 2.—
Tapping machine use.....	\$ 5.—
Loader use.....	\$ 7.—
1 street cut: 4' x 2' Oil and gravel.....	\$

Service Leak

January 6, 1961

E. S. Lafayette St., N x Brooklawn Ave. 204.4 ft.
#206 Lafayette St.

Service #25833 corporation was pulled out of the
main. A repair saddle was installed at main:

1-6"x8" Smith-Blair DC-20-7E Repair Saddle

1 street cut: 5' x 5' Warrenite

Compressor: Ingersoll-Rand 1 hr.

Loader 1 hour

LeRoi compressor: 2 hrs.

Langlois

LeClair

Camara

Fernandes

