

c/o Paul G. Cleary & Co.,
261 Union St. Tel. 4-6451

#25952 Alberox Corporation
N. S. Braley Rd. Extension, W x Braley
Road

Please install 3" Taker's Meter and
3" Copper Service to supply mfg. plant.
To line only.

Measures of 3" Tapping Gate Valve:

E x E line of Industrial Park Rd.	85.3 ft.
N x S line of Braley Road <i>Ext.</i>	24.4 ft.
E x W line of building	4.2 ft.

Work done on July 17, 18, 19, 20, 1961.

(over)

P 86 ft. of 3" copper tubing type K, soft.....	\$ 245.10
Labor.....	195.12
P 1-3" Darling Tapping Gate Valve.....	
P 1-16" x 16" x 3" Tapping Sleeve, A.P. Smith.	
1-4" C.I. Gate Box, complete - 209 lbs.....	
2-4" C.I. Round Gate Box Risers.....	
P 1-3" Cop. to Hub Caulking Nipple(H.D.).....	
P 4-3" x 3" cop. to cop. cplgs., A-1775.....	
5½-lbs. of caulking lead.....	
18-lbs. of leadite.....	
1½-lb. of braided jute.....	
Tapping Machine Use.....	10.--

See Ser. #25951 for carting, supervision,
equipment use and street cut - Both ser-
vices were laid in the same trench.