

264 Davol St., Fall River
July 24, 1961

#25973 Moss Construction Co., Inc.
W.S. Mt. Pleasant St., S x Nausett St.

Please install 6" C.L.C.I. Fire Supply
to supply building. To lot line only. Tap
30" main.

Measure of 6" Tapping Gate Valve:

S x S line Nausett St.	283.5
E x W " Mt. Pleasant St.	10.6
N x S " Building	1.8

Work done August 15. 16 & 17, 1961

Service tapped into west main

(over)

16 ft. of 6" C. I. cement lined pipe \$
 1-6" O-ring tapping gate - Darling.. \$
 1-30"x30"x6" tapping sleeve-A.P.S... \$
 1-4" C. I. gate box, complete. #220#.. \$
 36 lbs. leadite..... \$
 2 1/2 lbs. braided jute..... \$
 Tapping machine use... (Drilling).... \$
 1 st. cut: 16' x 2 1/2' Warrenite..... \$
 1 st. cut: 8' x 5' Warrenite..... \$
 1 sidewalk cut: 8' x 5' dirt.....

13.--

See Service #25972 for labor, carting,
 supervision and equipment costs.
 Both services laid into same trench