

Tel: 5-3623

29 Tarkiln Hill Rd.

July 27, 1961

#25980 Adelard Vaillancourt

S.S.#106 Washington St., E x Bonney St.

Please install 6" C.L.C.I. Fire Supply
to supply nursing home. To line only.

Measure of 6" Gate Valve:

E x E line Bonney Street 123.1

N x S " Washington Street 12.4

E x W " House 7.3

Work done August 15, 16, & 16, 1961

Laid in same trench with Service #25979

-1-6" PIPE STAMP \$6.- (over)
added by plume. (PLUMBER
CAME FOR IT)

P 31.4 ft. of 6" Cast iron cement Lined SP\$.
 Labor.....\$ 160.92
 P 1-6" 1/2 Bend, Bell & Spigot, 72" long...\$
 P 1-6" Straight Flange & Spigot, 18" Pipe\$
 P 1-6" Offset, Bell & Spigot, Cement lined
 12" center to center...\$
 P 1-8" on 6" Tapping Sleeve - A. P. Smith..\$
 P 1-6" Tapping Gate - O-ring - Darling...\$
 P 1-6" C. I. Gate Box, complete - 224 lbs\$
 Carting.....\$ 15.--
 Tapping Machine use. (Drilling).....\$ 13.--
 10 lbs. leadite.....\$
 23 1/2 lbs. caulking lead.....\$
 2 lbs. braided jute.....\$
 Supervision.....\$ 23.92

1-6" PIPE
 6 1/2' x 1 1/2'

See Service #25979 for XXXXXX Cuts
 AND EQUIPMENT