

Tel: 9-6451

Braley Rd. Extension

Aug. 18, 1961

#25989

Boston Nickel Plating Co. Inc.
S.E.Cor. Braley Rd. Ext. &
Industrial Park Drive.

Please install 8" C.L.C.I. Fire
Supply to supply mfg. plant.

Measure of 8" Gate Valve:

| | |
|----------------------------------|-------|
| E x E line Industrial Park Drive | 349.9 |
| N x SS " Braley Rd. Ext. | 18.5 |
| E x E " Building | 30.6 |

Work done August 23 & 24, 1961

(over)

| | | | |
|---|---------------------------------------|----|--------|
| P | 2½ ft. of 8" C. I. Cement Lined Pipe. | \$ | |
| | Labor..... | \$ | 223.76 |
| P | 1-16"x16"x8" tapping sleeve - A.P. S. | \$ | |
| P | 1-8" O-ring Tapping Gate - Darling... | \$ | |
| | 1-6" C. I. gate box, complete, 232#.. | \$ | |
| P | 1-8" Offset, Bell & Spigot, 294 # - | \$ | |
| | W. W. E..... | \$ | |
| | Carting..... | \$ | 15.-- |
| | Tapping machine use.(drilling)..... | \$ | 15.-- |
| | 33 lbs. leadite..... | \$ | |
| | 2 lbs. braided jute..... | \$ | |
| | 1 street cut: 15' x 5' Warrenite.... | \$ | |
| | Supervision..... | \$ | 23.92 |

See #25988 for for equipment use. Both services went into the same trench.