

May 18, 1962
#26122 Roman Catholic Bishop of Fall River
S.W. Cor. #405 County & Clinton Sts.

Please install 6" C.L. Cast Iron Fire
Supply to supply day nursery. To streetline
only.

Measure of 6" O-Ring Tapping Gate Valve:

W x W line County St. 108.3

N x S " Clinton St. 13.0

W x E " House 29.5

Main is 14 ft. N x S line

Work done June 4, 5 & 6, 1962

21.

(over)

1-6" x 6" x 6" TAP SLEEVE A.P. Smith

15' of 6" C. I. C. L. pipe: 13' Cut.- 2' In..	
Labor.....	\$145.80
1 6" Darling O-ring Tapping Gate Valve.....	\$
1 6" Gate Box, complete - 224 lbs.....	\$
Ca. ting.....	\$15.--
Loader use.....	\$21.--
Compressor use.....	\$24.--
Tapping machine use (drilling).....	\$13.--
1 4" Round C. I. gate box riser - 52 lbs.....	\$
16 lbs. leadite.....	\$
1 lb. braided jute.....	\$
1 street cut: 7' x 5' Warrenite/.....	\$
1 sidewalk cut: 4' x 4' concrete.....	\$
Supervision.....	\$23.92

per W. Board