

Tel: 6-8241

545 Pleasant St.
August 21, 1962

#26180 First Safe Deposit National Bank
N.E.Cor. Acushnet Ave. & Jireh St.

Please install 1" City Meter & 1"
copper service to supply bank building. Lay
with drain if possible.

Measure of 1" Curb Stop:

N x N line	Jireh St.	26.0
W x E	" Acushnet Avenue	10.0
S x N	" Building	5.3

Main is 47 ft. W x E line

Laid with drain

Work done Sept. 11, 1962

(over)

Labor.....	\$	53.04
1 1" corporation, fig. 438 - Red Hed....	\$	
1 1" cop. to cop. stop, fig. 415 - R.H....	\$	
1 Caldwell stop box, complete - long....	\$	
Carting.....	\$	2.--
Tapping machine use.....	\$	5.--
Loader use.....	\$	7.--
Compressor use.....	\$	6.--
1 street out: 8' x 2 $\frac{1}{2}$ ' Warrenite.....	\$	

Owner's plumber supplied & installed 60 ft.
 of 1" copper tubing type K, soft from main
 to meter inside building.
 47' out. 13 ft. ins.