

1 Sycamore St.

Aug. 27, 1962

#26183

State Armory

Comm. of Mass.

N.W. Cor. #1 Sycamore & Pleasant St.

please install 4" C.I.C.L. Fire

Supply to supply state armory. Lay with 2" Cop.
ser. #26182. Replace Ser. #10505.

Measure of 4" O-ring A. B. Gate Valve:

W x W line Pleasant St. 94.6

S x N " Sycamore St. 5.0

E x W " Building 10.3

Main is 24 ft. S x N line

Work done September 12 & 13, 1962

This 4" service goes through a 3 ft. brick
wall

(over)

24' out. 24' in.	
48' of 4" cast iron cement lined pipe.....	
Labor.....	\$5.02
1 4" 1/8 bend, bell & spigot, S. P. Cement lin.	
1 4" solid sleeve.....	
1 4" O-ring All Bell Gate Valve - Darling.....	
36 lbs. leadite.....	
2 1/2 lbs. braided jute.....	
2 street cuts: 11' x 2 1/2' Warrenite &	
4' x 3' Warrenite.....	
1 sidewalk cut: 4 1/2' x 3 1/2' cement.....	
1 4" cop. to hub caulk. conn.- City Brass.....	
Loader use.....	7.—
Compressor use.....	6.—
Carting.....	10.—
Supervision.....	19.79

The old 4" C. I. gate box was reused