

#26332

May 21, 1963
Dept. Public Works
S.W. Cor. #311 Liberty & Parker Sts.

Please install 4" C.L.C.I. Ser.
and 3" City Meter to supply truck wash. NO
CHARGE - per Water Board.

Measures of 4" Darling Tapping Gate Valve:

W x W line Liberty Street	87.5
N x S " Parker Street	15.5
E x W " Building	10.8

Main is 18 ft. N x S line

Work done May 21, 22 & 23, 1963

(over)

55.6' of 4" Cast iron cement lined pipe	
18 ft. out. 37.6 ft. inside	
1 12"x12"x4" A.P. Smith tapping sleeve..	
1 4" Darling Tapping gate valve.....	
1 4" C. I. gate box, complete - 209 lbs.	
Carting.....	\$ 15.-
Tapping machine use.....	\$ 11.-
1 4" solid sleeve.....	\$
38# leadite.....	\$
2 1/2# braided jute.....	\$
1 4" 1/4 bend, bell & spigot, cem. lin.	\$
Compressor use.....	\$ 3.--
1 st. cut: 8' x 4' Warrenite.....	\$
1 sidewalk cut: 4' x 2' cement.....	\$
Labor (cost).....	\$171.50