

c/o Paul G. Cleary 1125 County St.

Mar. 24, 1964

#26611 Charles E. Sharek

S.W.Cor. #139 Ashley Blvd. & Holly
St.

Please install 6" Fire Supply(C.I.C.L.)
to supply pharmacy. Will notify when ready.

Measures of 6" O-ring Gate Valve:

W x W line Ashley Blvd.	53.6
N x S " Holly Street	17.0
E x W " Building	10.6

Main is 18 ft. N x S line

Work done April 2 & 3, 1964

This service was installed in the same trench
as Service #26610.

14.4 ft. of 6" C. I. inside prop ty line	
1 2 ft. inside prop ty line	
14.4 ft. of 6" C. I. Cem. Lin. Pipe...	
Labor.	133.08
1 6" O-ring Darling Tapping Gate Val.	
1 6" C. I. gate box, complete - 224#	
1 6"x6"x6" A.P.S. Tapping Sleeve. . .	
Drilling machine use.	20.--
Carting.	10.--
1 6" 1/4 bend, Flange & spigot,	
cement lined, 5 ft. long.	
1 6" spigot pipe strap.	6.--
Loader use.	10.50
Compressor use.	9.--
16 lbs. Mineralead.	
1 lb. braided jute.	
1 street cut: 8' x 4' Warrenite. . .	
1 sidewalk cut: 10' x 3' Dirt. . .	
Supervision.	26.70