

c/o Paul G. Cleary Co., Inc. 1225 County St.

April 7, 1964

#26622 Electralab Printed Electronics Corp.

~~E.S. Duchaine Blvd.~~ 1300 ft. S x
INDUSTRIAL PARK DRIVE
Braley Rd. Ext. ROAD

Please install 4" C.I.C.L. to supply
Printed electronics plant. To property line
only.

Measures of 4" Tapping Gate Valve:

S x S line Braley Road	EXT.	1389.0
W x E " Industrial Park	ROAD	25.5
S x S " Building		19.7

Main is 27 ft. W x E line

Work done April 30, 1964

(over)

In same trench as Service #26623

39' of cast iron cement lined pipe... \$
 22' outside 11' inside

labor . . . \$

1 1/2" on 4" tapping sleeve, A.P. Smith.
 1 1/2" Darling tapping gate valve.
 1 1/2" C. I. Gate box, complete, 209#.

2 1/2" offsets, B & S, Gen. Ltn. 1200 to 100

32 lbs. mineral lead.
 2 lbs. braided jute.

cutting . . .
 tapping machine use. . .

motor use. . .
 loader use. . .

superstation. . .

See Service #26623 for pipe & cut -
 both services in same trench.

\$54.36

15.00
 14.00
 2.00
 67.00