

200 Union St., Braintree, Mass. Tel: 5-8267

June 9, 1964

#26718 Grossman Industrial Properties, Inc.
W.S.#355 Church St., N x Irvington
St.

Please install 8" C.L.C.I. Fire
Supply to supply store. To property line only.

Measures of 8" Tapping Gate Valve:

N x N line Irvington St.	360.0
E x W " Church St.	18.4
S x S " Building	3.0

Main is 20 ft. E x W line
Line Service

Work done June 29, 1964

(over)

19' of 8" C. I. cement lined pipe. .	
Labor.	109.20
1-8" Darling O-ring Tapping G. Valve	
1-12" on 8" A. P. S. Tapping Sleeve	
1-6" C. I. gate box, complete, #24#.	
Carting.	10.00
Drilling Machine Use	20.00
Motocrane Use.	14.00
Loader use	7.00
Compressor use	4.50
32 lbs. Mineralead	
2 lbs. Braided jute.	
1 st. cut: 15' x 5' Warrenite . . .	
1 sidewalk cut: 10' x 5' dirt . . .	
Supervision.	20.02

Service #26717 - 2" was installed inside
the same trench.