

54 State Rd., No. Dartmouth, Mass.

November 13, 1964

#26856 George E. Carter  
S.E. Cor. Oakdale & Roseanne Sts.

Please install 1" Copper service  
to supply bungalow. Main to be extended.

Measures of 1" Curb Stop:

E x E line Roseanne St. 48.0

N x S " Oakdale St. 6.5

E x W " House 1.6

Main is 14 ft. N x S line

Work done December 8, 1964

Oct. 18, 1965: The 1" corporation  
was tapped in line with the curb stop. (over)

~~Sketch Attached~~

~~The 1" corporation is 1.5 ft. W x terminus  
of 8" main~~

88' of 1" cop.: 24.5' Ins. 63.5' out.	\$	12.22
Labor. . . . .	\$	19.02
1 1" corporation, fig. 438 - Red Red	\$	
1 1" cop. to cop. stop, fig. 415. . .	\$	
1 Caldwell stop box, complete - long	\$	
Carting. . . . .	\$	5.00
Tapping machine use. . . . .	\$	5.00
Motorcrane use. . . . .	\$	14.00
Loader use . . . . .	\$	7.00
Compressor use . . . . .	\$	1.50

Service Repaired  
S. E. Cor. Oakdale & Roseanne St.

October 18, 1965

Service #26856 is now tapped on a straight line directly into the newly extended 8" main pipe. The excess 1" copper tubing was removed and returned to the repair shop.

The 1" corporation was removed and inserted into it's new position - on a line with the curb stop.

The 1" brass plug, reinforced thread, fig. 45 - Red Hed was used to plug Frasier, F. <sup>40/e</sup> left by the removal of the 1" Corporation.

This work was done while the 8" main pipe was Being extended.

