

6-8234 c/o Paul G. Cleary, P. O. Box D 807

March 10, 1965

#26946 Supesah Realty Trust

E. S. Duchaine Blvd., S x Braley Rd. Ext.

Please install 6" C. I. cast iron fire
supply to supply Printing Co. Bldg.

To street line only.

Measures of 6" Tapping Gate Valve:

S x S line Braley Rd. Ext.	937.0
W x E " Duchaine Blvd.	26.5
S x S " Building	21.6

Main is 27 ft. W x E line

Work done March 15, 1965

(over)

36' of 6" Cast Iron Cem. Lin. Pipe.	
26.5' out. 9.5' ins.	
Labor.	151.92
x 1-16"x6" tapping sleeve - A. P. Smith.	
1 6" Darl. tapping gate valve - o-ring.	
1 6" Cast Iron gate box, complete - 224#	
1 6" Offset, B & S, Cem. Lin. - 12"CtoC \$	
32# Mineralead.	
2# braided jute.	
1 street cut: 27' x 4' dirt	
Motocrane use.	28.--
Compressor use	6.--
Drilling Machine use - A. P. Smith	20.--
Carting.	10.--
Supervision.	20.16

Installed in same trench together with
Service #29645