

Augustini Const. Co. Inc
70 Beacon St. Pawt.R.I.

September 13, 1965

#27093

Suzanne Realty Corporation

E. W.S. Bolton St. N x Rockdale Ave.

Please install 6" C.L.C.I. service to supply
supermarket.

Measures of 6" Tapping Gate Valve:

N x N line Circuit St.	29.0
E x W " Bolton St.	19.0
N x S " Building	11.7

Main is 40 ft. E x W line

Work done September 14, 15 & 16, 1965

(over)

✓ 36' of 6" Cast iron cement lined pipe:
 Main to 3 ft. outside property line. \$
 Labor. \$180.54
 1 6" Darl. O-ring Tapping Gate Valve . . . \$
 1 10"x10"x6" A.P. Smith Tapping Sleeve . . . \$
 1 6" C. I. Gate Box, complete - 22 1/2 lbs. . . \$
 Carting. \$ 30.--
 A. P. Smith Drilling Machine #54 . . . \$ 20.--
 20 lbs. Leadite. (Mineral lead). \$
 1 1/2 lbs. braided jute. \$
 Loader use. \$ 10.50
 Compressor use. \$ 3.--
 1 st. cut: 30' x 2' Warrenite. \$
 1 sidewalk cut: 10' x 2' Dirt
 Supervision. \$ 42.27
 Laid with Service #27094 - 2"