

Tel. 6-6751

#27273

June 28, 1966

Sacred Hearts Nursing Home

E. S. Cottage St., S x Austin St.

Please install 6" C.L.C.I. service to supply
Convalescent home. Off 8" Y. Meter inside
meter pit inside property.

c/o J. Coholan

703 So. Water St.

Measures of 6" All Bell Gate Valve:

S x S line Austin St.	71.5
W x E " Cottage St.	2.9

Measures of 8" x 6" Reducer:

S x S line Austin St.	71.5
W x E " Cottage St.	7.2

Main is 30 ft. W x E line

Work done Sept. 27 & 28, 1966

5.6 ft. of 6" Cast iron cement lined pipe . . .	\$	
Labor.	\$	131.54
81 lbs. Mineral lead @ .16 lb.	\$	12.96
5.1.3. lbs. Braided Jute @ .80 lb.	\$	4.00
Loader use.	\$	10.50
Compressor use.	\$	4.50
1 Sidewalk cut: 10' x 4' Cement - E. S. Cott. .	\$	
Carting.	\$	20.00
S54 Tapping machine use - A. P. Smith.	\$	20.00
Supervision.	\$	25.20
20 ft. of 8" Cast iron cement lined pipe . . .	\$	

Owner supplied the following stock:

- 1 6" Gate Valve, All Bell - Darling - O-ring
- 1 8" x 6" Reducer, Bell & Spigot, Cement Lined
- 1 8" x 8" x 6" Tee, All Bell, Cement Lined
- 1 6" C. I. Gate Box, Complete - 224 lbs.

Work done September 26 & 27, 1966: Installing main
pipe in Cottage St., S x Austin St. for Services
#27273 - 6" and #27274 - 6":

Charges:

Labor.	\$ 168.58
Supervision.	\$ 31.72
Loader use	\$ 21.00
Compressor use	\$ 6.00
1 Street cut: 23' x 2 $\frac{1}{2}$ ' Warrenite - E. Side	\$
1 Street cut: 9' x 7' Warrenite - W. Side .	\$

Owner Supplied the Following Stock:

1	30"x30" x8" A. P. Smith Tapping Sleeve
1	8" Darling Tapping Gate Valve - O-ring
1	8" C. I. Gate Box, Complete - 245 lbs.

