

Tel. 6-6751

#27274

June 28, 1966

c/o J. Coholan
703 So. Water St.

Sacred Heart Nursing Home
E.S. Cottage St., S x Austin St.

Please install 6" C.L.C.I. service to supply
Convalescent home. Off 8" Y. (future bldg.)

Measures of 6" Gate Valve:

S x S line Austin St. 75.0

W x E line Cottage St. 8.2

The 6" Cast iron plug is inserted into the 6" gate
valve. The terminus of the 6" Fire Supply is
76 ft. S x S line Austin St.

Work done Sept. 27, 1966

2 ft. of 6" Cast Iron Cement Lined Pipe.	\$	
Labor.	\$	59.58
12 lbs. Mineralead @ .16 lb.	\$	1.92
3/4 lb. Braided Jute @ .80 lb.	\$	.60
Carting.	\$	10.00
Loader use.	\$	10.50
Compressor use	\$	3.00
1 Sidewalk cut: 4' x 4' Cement - E. Side Cott.	\$	
Supervision.	\$	11.92

Owner supplied the following stock

- 1 6" Darling Gate Valve, All Bell - O-ring
- 1 6" C. I. Stop Box, complete - 224 lbs.
- 1 6" Cast iron plug