

Box D 807

November 4, 1966

#27417

Southeastern Mass. Develop. Corp.

W.S. Duchaine Blvd.

S x Theodore Rice Blvd.

Please install 6" C.L.C.I. Fire Supply
service to supply Plant.

MEASURES OF 6" GATE BOX;

SOUTH FROM CENTER OF LAST HYDRANT ON

W.S. DUCHAINE BLVD.,

9. ft.

S. FROM BRALEY RD.

9.6 FT.

E. FROM ABOVE HYDRANT

4.0 FT.

WORK DONE FEB. 20, 1967

18 ft. of 6" C.I.C.L. PIPE	Bell Spigot.		\$
1.6 ft. of 6" C.I.C.L. Pipe	Spigot Spigot		\$
Labor			\$
1-10" X 10" X 6" C.I.C.L. Tee	N.B.W.W.		\$
1-6" C.I.C.L. PIPE	Round gate box. Complete Reg.		\$
1-6" Mueller	O-ring gate box valve. (all bell)	. . .	\$
3-6" MINERALEAD JOINTS AND GASKETS.			
Lorain Moto Crane	$\frac{1}{2}$ hr.		\$
Massey Ferguson	1 hr.		\$
Street cut 20' X 2 $\frac{1}{2}$ ' Dirt			

Contractor will maintain all cuts.

W.S. DUCHAINE BLVD.
S X BRALEY RD.