

Adamsville, R. I.

June 2, 1967

#27500

Manuel F. Avila

S. S. Coffin Ave., E. x Riverside Ave

Please install 6" C.L.C.I. FIRE SUPPLY to
supply building.

MEASURES OF 6" TAPPING GATE:

E X E LINE RIVERSIDE AVE.

84.5

N X S LINE COFFIN AVE.

14.0

WORK DONE JUNE 5, 6, 1967

25.6 ft. of 6" Cast iron pipe C. L.	4
Labor	4
1-8" X 8" X 6" A. P. Smith tapping sleeve. .	4
1-6" A. P. Smith O-Ring tapping gate valve . .	4
1-6" Round iron gate box. Complete Reg. Pattern	4
1-6" Bell and "pigot pipe strap. Less rods & nuts	4
2-8" Mineralead joints and gaskets	4
3-6" Mineralead joints and gaskets	4
A. P. Smith S-54 tapping machine.	4
Oliver loader 2 hrs. /	4
Ingersoll Rand Comp. 1 1/2 hrs.	4

Street cut 10' X 3' Barrinite	S. S.
Side walk cut 8' X 3' Cement	S. S.