

Tel. 2-4242

#27569

City Hall

September 14, 1967
New Bedford
New Bedford Water Department
George Brightman, Superintendent

NO. # 1105 W. S. Shawmut Ave., S. x Nash Rd.

Please install 8" C.L.C.I. (6" meter) service
to supply maintenance shop. To tap 8" main in
Shawmut Avenue. Meter: inside building in meter
room.

MEASURES OF 8" TAPPING GATE:

S X S LINE NASH ROAD	246.5
E X W LINE SHAWMUT AVE.	33.0
S X N LINE BUILDING	45.0
E X E LINE BUILDING	130.2

THE MAIN IS 33 FT. E X W LINE

WORK DONE SEPT. 11, 12. 1967

125 ft. - 8" Cast iron C.L. Pipe \$
 6 ft. - 8" Piece C.I.C.L. Pipe spigot.spigot . . . \$
 6 ft. - 8" Piece C.I.C.L. pipe spigot spigot . . . \$
 1-8" Bend Cement lined Bell Spigot 4 ft. long Build.
 1-8" Solid sleeve \$
 1-8" Round iron gate box Complete Reg. Patt. . . \$
 A. P. Smith Tapping machine use (Old) \$
 1-8" X 8" X 8" Tapping sleeve A. P. Smith \$
 1-8" Tapping gate valve (O-Ring) Darling \$
 13-8" Mineral lead joints and gaskets \$
 1-8" Off set 18" Center to center Bell Spigot
 (4 ft. long cement lined.)

Street cut 24' X 3' Warrenite W. S.

Side walk cut 10' X 3' Dirt W. S.

1-8" Pipe clamp at foundation of building (Cont.)

Wednesday June 7, 1967

NO SERVICE
NUMBER!

Service installed at new building site.

Shawmut Ave. - WATER DEPT. REPAIR
Stop. box. SHOP

W X W line Shawmut Ave.

Corp. tap is 5 ft. E X pole No. 7726 314.0 ft/

Stop box is 6 ft. E X Pole No. 7726

Stop box is 13.6 ft. N X Pole No. 7726

Stop box 15.0 ft. S X S line Shawmut Ave.

1" Copper tubing used.

POLE # 7726 - 4TH POLE W X
SHAWMUT AVE ON ROAD TO
INCINERATOR.

5.6 ft. - 1" from main to curb stop.

14. ft. - 1" from curb stop to 5 ft. above ground.

1- Caldwell stop. box Long bottom

1" X 6" Mueller Saddle

1-1" corp. tap. Mueller

1-1" curb stop. Mueller

D-4 Tapping machine

Vieira

Letendre

Frasier

No shovel used.

THIS SERVICE IS FAUCET ON THE
SS OF BLDG AT REPAIR SHOP -
USED TO WASH TRUCKS