

Acushnet Comp.

June 12, 1968

#27714

Acushnet Company/William E. Flack
S. S. Slocum St.

E. x Acushnet River, Acushnet, Mass

Please install 12" C. L. C. I./ 6" meter.

Agreement with City of New Bedford work performed by private contractor at Taker's expense.

Meter: in pit at City line.

MEASURE OF 12" TAPPING GATE VALVE.- BELLEVILLE AVE.

N X S LINE WOOD ST. 4.0

E X W LINE BELLEVILLE AVE. 19.6

12" MAIN GATE- W X RIVER RD.

W X W LINE RIVER RD. 75.0

N X S LINE WOOD ST. 5.5

All Stock By Contractor

808.6 ft. - 12" C.I.C.L. TYTON PIPE. \$
 1-12" Darling tapping gate valve O'ring \$
 1-12" X 12" X 12" Darling tapping sleeve \$
 5-12" Darling gate valves o'ring (Mech. joint) \$
 3-12" $\frac{1}{4}$ bonds Mech. joint. \$
 6-12" $\frac{1}{8}$ bonds Mech. joint \$
 2-12" X 12" X 12" Cast iron tees Mech. joint \$
 2- 12" mineral lead joints and gaskets. \$
 2-12" lead joints and gaskets \$
 6-8" round iron gate boxes. Complete Reg. Pat. \$
 1-12" X 12" Cast iron C.L. Offset Bell Spigot \$
 All bends are rodded and truss block poured behind
 tees and bottoms of bends.

#27724 - 12"

River Rd. Connection	Stock used.
12.6 ft. - 8" Cast iron C.L.	Tyton Pipe . . . \$
1-8" X 8" X 8" Darling tapping sleeve	. . . \$
1-8" Darling tapping gate valve	o'ring . . . \$
1-12" X 12" X 12" Tee (Meech joint)	. . . \$
1-8" Bend (Meech joint)	. . . \$
2-8" mineraloed joints and gaskets	. . . \$
1-8" lead joint and gasket	. . . \$
1-8" round iron gate box.	Complete Reg. Pat. \$

Measure of River Rd. Tap.

8" X 8" X 8" Tapping sleeve	
S X S line Wood St.	3.1
E X W line River Rd.	13.0

8" Tapping Gate

S X S line of Wood St.	3.1	E X W line River Rd.	12.0
------------------------	-----	----------------------	------

3" $\frac{1}{2}$ Bond

S X S line Wood St.	3.1
E X W line River Rd.	5.8

12" X 12" X 8" Tee (In Wood St.)

N X S line Wood St.	5.0
E X W line River Rd.	5.8

1st. Tee 12" X 12" X 12"

E X E line River Rd.	84.9
N X S line Wood St.	3.0

1st. Main Gate

E X E line River Rd.	87.4
N X S line Wood St.	3.0

#27714-12"

1st. By- Pass Gate

E X River Rd. 90.3

N X S line Wood St. 11.0

2nd. By-Pass Gate

E X E line River Rd. 100.5

N X S line Wood St. 3.0

2nd. 12" X 12" X 12" Tee

E X E line River Rd. 103.8

N X S line Wood St. 3.0

2nd. Main Gate

E X E line River Rd. 106.9

N X S line Wood St. 3.0

12" Bend

E X River Rd. 109.6

N X S line Wood St. 3.0

Extended 12" C.I.C.L. pipe from Belleville Ave. main
easterly to meter box. E X River Rd.

Main pipe is 3 ft. from River Rd. to meter box.

River Rd. is 40 ft. wide.

Service # 27714-12"

Acushnet Co..

S.S. Slocum St.

E X Acushnet Ave.

Attention : Muriel

Measures of 12" main gate valve.

E X E line River Rd. 87.4

N X S line Slocum St. 3.0

