

587 Acush. Ave.

#27784

September 11, 1968
Cape News Company
W. S. Frontage Rd.
N. x Potomska St.

Please install 1" copper service to supply warehouse and office. Contractor will extend from property line to inside building. 8" C.I. reduced to 1" copper. Meter: inside building. NO CHARGE.

Measures of 8" Gate Valve:

S x S line	So. Barrows St.	89.2
E x W	" Frontage Rd.	9.2
N x S	" Building	41.0
E x E line	Building	40.2

Work done September 16, 1968
Stock Supplied & installed by Contractor

14 ft. of 8" Cast iron pipe
1-8" Darling Gate
1 - 8" Gate Box, Complete
30 feet of 1" copper inside - supplied by owner

This service is tapped off the 8" plug at property line. Campanalla installed an 8" C. I. service from the cross in street to property line with a mechanical plug at terminus. An 8" all bell gate was installed 2 ft. from main.