

Conway St.

#28064

October 22, 1969

Harriet Transport Co.

N.W. Cor. Conway St. & Cape St.

Please install 2" Copper service to supply trucking garage. Meter inside garage building. To be reduced from 8" C.L.C.I to 2" Copper from property line.

Measures of 8" Gate Valve - this Gate is the controlling valve for this 2" Service:

W x W	line Capeway St.	71.0
-------	------------------	------

S x N	" Conway St.	42.0
-------	--------------	------

E x E	" Building	9.0
-------	------------	-----

S x S	" "	62.6
-------	-----	------

Work done Jan. 14. 1970 by Owner's Contractor

Owner supplied and installed 45 ft. of 2" copper
tubing from the property line to inside bldg.

Service is on meter - By-pass sealed

Inspected by Poncelet