

22 Tarkiln Hill Rd.

April 30, 1970

#28176

D. J. Realty Corp.

S. S. Poplar Rd., W. x Hill Rd.

Please install 1" copper service to supply
bungalow. Meter: inside cellar wall. *Int 88*

Measures of 1" Curb Stop:

W x W line	Hill Rd.	277.0 ft.
N x S "	Poplar Rd.	5.0 ft.
E x W "	House	12.7 ft.
N x N "	House	33.3 ft.

Main is 14 ft. N x S line.

Work done July 15, 1970

Meter in Utility room in rear of house.

65½ ft. - 1" Copper by Owner: 14' out; 51½' ins

Labor. \$36.24

1 1" Hays Corporation 8.50

1 1" Hays Curb Stop. 14.00

1 Buffalo Stop Box, complete 10.00

Carting 10.00

D-4 Drilling Machine Use 15.00

2 1" Meter cplg. @ 2.50 ea. 5.00

98.74

Owner dug, backfilled & will maintain
trench cuts.

Owner supplied 8" x 1" Dresser Style 91
D.S. Saddle.